A wide-angle photograph of Niagara Falls, showing the water cascading over the rocky ledge and creating a large plume of mist. The surrounding landscape is lush with green vegetation.

# Small-scale thermal hydrolysis to optimise biosolids management Case studies from North America

Dr Bill Barber

13 November 2023

# Development of Modularized thermal hydrolysis



1998



2019



# Clinton River Water Resource Recovery Facility

20 t DS/d

Auburn Hills  
Charter Township of  
Independence  
Lake Angelus  
Lake Orion  
Oakland Township  
Orion Township  
Oxford Township  
the village of Oxford  
Pontiac  
Rochester  
Rochester Hills  
Waterford Township  
West Bloomfield Township


















# Wastewater treatment infrastructure



Headworks

Tertiary  
Filtration

Primary  
Clarifiers

Aeration  
Basin


Secondary  
Clarifiers

Disinfection

Clinton  
River




# Biosolids management infrastructure



- Primary with secondary digestion
- Dewatering
- Open storage area



# Mass Balance (Biosolids Processing)





# Drivers

- Insufficient digestion capacity
- Raw cake storage creates strong odours
- Reliance on landfill
- Preference for state-of-the-art facility
- Class A bonus but not necessity

## Optioneering study

- Additional digestion capacity
- Different digestion configurations
- Liming based systems





## New Infrastructure

Septage  
Receiving  
facility

Biosolids storage

Biosolids  
processing  
building

Biogas  
storage  
dome

Total Cost approx. \$42,000,000

Project received \$2.5 million principal forgiveness from Michigan's Green Project Reserve, funded by the Clean Water State Revolving Fund program.





**New biosolids handling building**

- 2-story building of 15,880 ft<sup>2</sup> with processing capacity of 550 kl/d concentrated sludge
- 2 x sludge blending tanks
- Hydro sludge screens receiving sludge at 3% DS
- 2 x Andritz centrifuge pre-thickening
- Cambi Thermal hydrolysis
- 2 x Andritz dewatering centrifuges





Thickening and dewatering





Source: Water and Wastes Digest Magazine, December 2021

**Thermal Hydrolysis**





Boiler plant





## Biogas storage dome

- Duosphere
- 2,300 m<sup>3</sup> storage capacity
- 6 hours





- 4 biosolids storage holding bays
- 20,000 sq ft storage area
- Can store 7000 cu. yards of biosolids
- Approx. 180 days

**Covered biosolids storage area**









# Anaerobic Digestion Performance

pH	8.0 ± 0
Alkalinity [mg CaCO3/l]	8,712 ± 458
Total VFA [mg/l]	732 ± 259
Ammonia-N [mg/l]	2,238 ± 484
VFA/Alkalinity ratio	0.08 ± 0.03





# Class A accreditation



■ EPA and State Regulations

■ Communications


■ New technology in Michigan

■ Benefits of Class A

► Potential for other outlets



# Mass Balance (After THP)



Sludge Input	
Tons/d	25
%DS	5
%VS	75
Wet tons/d	250

HRT < 30 d



DS% = 32%




DS% = 37%



Class A to Land application	
Tons/d	12.9
%DS	37
%VS	49
Wet tons/d	31.7

Digestion	
Number	2
Total vol. (m³)	5,300
%VSR	57
Biogas (m³/)	8,700

Storage	
Time	Weeks to months
Additional VSR%	25
Total VSR%	68 - 70






Raw to landfill	
Tons/d	0
%DS	N/A
%VS	N/A
Wet tons/d	0




# Performance

Cake Production



- 65% less cake
- Class A
- No landfill


Biogas production



- 350% more biogas
- Some biogas used for boiler
- Excess for plant use
- Some used for aeration




# Impact on operations





# Carbon footprint

## Contributions





# Planned Maintenance Shutdown

Sept 13 – 17<sup>th</sup> 2021

- First Planned shutdown delayed after 2 years partly due to COVID-19
- Approx. 1 week for THP plus 1 week for boiler plant – (typically <1 week for both)
- Despite COVID-19 delay key items in good condition
- Needed to landfill during shut-down







- Pre-dewatered cake hopper
- Single stage PC pump
- 4" stainless pipe to THP inlet
- 4" pipe changed to 8" HDPE pipe
- Mixing could be improved with the pump
- Recommend 4 stage pump, spend a little more money and eliminate any risk



# Observations



- Perception
  - Perceived complexity for new technology
  - THP was the easiest part of the plant to operate
- Ease of operation and maintenance
- High availability and reliable
- Excellent service and customer support





# Location

- Medina County, Ohio
- Approximately 35,000 homes and businesses
- Serves the cities of Brunswick and Medina, and several townships
- Located in the Lake Erie Drainage Basin









- 55,500 m<sup>3</sup>/d (15 t DS/d)
- Design flow
- Activated Sludge with EBNR
- Class A or Exception Quality Sludge
- 6 Primary Clarifiers
- 9 Aeration Basins
- 3 Final Clarifiers
- 3 Sand Filters
- TP < 1 mg/l
- Ammonia-N < 1.15 (summer) 4.5 (winter)



# ZIMPRO WET AIR OXIDATION

- Oxidized sludge at high temperature and pressure
- Produced EQ Biosolids
- Extensive training process for operators
- Energy Inefficient
- Difficult and Expensive to maintain
- 40 + years old
- \$17 M to refurbish





# 2015 Assessment of Plant Capacity – Investment Grade Audit (IGA)

- Increasing COD Loading in the Influent
- Increasing problems with recirculation of refractories
- High Energy and maintenance costs with Zimpro





# Results of the IGA

- Replace aging sludge processing infrastructure
- Reduce Operational Costs
- Expand capability to process External Waste Sources as part of Sludge Stream
  - ▶ Currently discharged into sewers – large load on main treatment process
  - ▶ Combined Heat and Power System
  - ▶ Estimated electricity savings of \$1.7M/year



Key Components



Two Anaerobic  
Digesters



Centrifuges  
dewatering

Everyday  
**Low Price**

**\$ 35 M**



Strength Waste  
Receiving



at Marks Road Lift  
Station



# Energy Savings Performance Contract



- Performance contract that guarantees the energy savings to a client.
- The savings in energy costs can be used to pay back the capital investment of the project over the useful life expectancy of the equipment.
- The contract may include energy validation requirements. These energy usage is verified after the system is commissioned and may require third party involvement.





# Project Timeline

NWWC  
2023



**2015**

Analysis of  
Plant  
Capacity

**December  
2016**

Investment  
Grade Audit  
Completed

**May 2017**

Construction  
began


**December  
2018**

Digester  
Seeding

**January  
2019**

Start-up












# Co-digestion





- Accepts FOG and DAF Solids and local food waste
- Preheated from Generator Cooling Loop
- Used for Dilution of THP Feed



- 
- A vintage black and silver television set is positioned on a dark wooden surface against a textured grey wall. The TV's screen displays a light blue background with a list of five bullet points in dark blue text. To the right of the screen, the TV's control panel features a circular dial with directional arrows, three small indicator lights, three rotary knobs, and two large rectangular speaker grilles.
- **Seed From Washington DC**
  - **First Load December 6, 2018**
  - **Total of 14 trucks approximately 22 dry tons each**
  - **Last load January 28, 2019**
  - **Started feeding digester in early January**



## Since Installation



# Lessons learnt

- It gets cold in Ohio
- Feed solids to THP needed to be increased
- Access to plant
- Proximity of spare parts
  - Stators for pumps





# Acknowledgements



**Dawn Taylor**

Superintendent at Medina County  
Sanitary Engineer



**Mike Daniels**

Chief WRC Water Resource Recovery at  
Oakland County Water

**Dr Bill Barber**

Technical Director Cambi. Inc.

Bill.barber@cambi.com

**Thank you**

Contact us

**CAMBI**

