

Calgary




For: 2024 NWWC  
By: Jifan Liu P.Eng  
2024-11-5

# Cogeneration Expansion Project Bonnybrook Wastewater Treatment Plant

# Calgary, Alberta, Canada

## Bonnybrook WWTP

- Largest one of the three WWTPs
- Serving 1.17 M population
- Average flow treated: 360 MLD







## Power Generation and Heating Facility (PGH)

- Plant process & space heating
- Plant normal & standby power



# Simplified Biogas Flow

Digester



Biogas  
Conditioning



Co-gen



Power &  
Heat





## Project description

- Adding a new 5 MW co-generation plant to existing Power Generation and Heat (PGH) facility
- Utilizing biogas to generate electricity and steam



## Project Objectives



- Fully utilize freely available biogas
- Double the plant onsite energy production – Cost savings
- Effort to achieve electrical energy self-sufficiency
- Produce steam for future thermal hydrolysis process (THP)
- Improve electrical system availability and reliability
  
- Minimize or eliminate flaring of biogas
- Reduce GHG emissions



## Co-gen options

- Reciprocating engine
- Gas turbine





## Digester gas / biogas

- Biogas – a byproduct from sludge digestion
- Biogas production- 1700 SM<sup>3</sup>/H
- Biogas - 2/3 of the heating value of Natural gas





# Bonnybrook raw biogas and typical natural gas composition

Constituent	Quantity
Methane	62%
H2S	3000 ppm
Siloxane	70 mg/m <sup>3</sup>
Carbon Dioxide	38%
Fuel Heating Value (LHV)	621 btu/scf

Constituent	Volume %
Methane	92.79 %
Ethane	4.16 %
Propane	0.84 %
N-Butane	0.18 %
N-Pentane	0.04 %
Nitrogen	1.51 %
Carbon Dioxide	0.44 %
Fuel Heating Value (LHV)	983 btu/scf



## Old PGH

- IC Engines
- Hot water Boilers
- Flares





## Existing Internal combustion engines


- CAT G3520C
- 3 x 1.6 MW

# Existing & New


Existing IC engine building

New Co-gen plant

Existing boiler building



ISOMETRIC VIEW - SOUTHWEST







# Co-gen expansion








### Bonnybrook WWTP: B09B Cogen Overview

Maintenance

Cogen Dashboard

Name	Value
Glycol Cooler 1(Running Fan Pairs)	0
Glycol Cooler 2(Running Fan Pairs)	0
Glycol Cooler 3(Running Fan Pairs)	0
Glycol Cooler 4(Running Fan Pairs)	0



Name	Value
CTG Fast Shutdown Command	INACTIVE
CTG Ramp Shutdown Command	SHUTDOWN
Prime Mover T5 Temperature Control Mode	OFF
Generator AGC Control Biogas Fuel Blend	47.0



# A Complex Integration of Many Packages

## Biogas → Turbine → Electricity and Steam

### ■ Biogas Conditioning

- Siloxane removal
- gas compression
- Filtration
- Dehydration
- Mixing

### ■ Generators

- Gas turbine
- Steam turbine

### ■ Electrical Distribution System

- Medium Voltage Switchgear
- 600V Switchgear
- 600V Motor Control Centre
- Power Management Control System

### ■ Distributed Control System

- Delta V

### ■ Steam System

- HRSG
- STG
- Standby steam boiler
- Steam surface condenser
- Cooling system


### ■ Water Treatment

- De-chlorination
- Water Softener
- Multimedia Filter
- Reverse Osmosis
- Electro De Ionization
- Deaerator
- Chemical Dosing

# Gas turbine (CTG) - 4.5MW




Bonnybrook Cogeneration Expansion - Combustion Turbine Generator






# Steam Turbine Generator (STG)- 0.5MW





# Siloxane removal




Ref No. Sample ID/Description	Beginning of Cycle		Ending of Cycle	
	23121908 RDG3sru1 1213231510	23121804 TDG3sru1-1 1213231510	23121909 RDG4sru1 1215231250	23121806 TDG4sru1-48 1215231252
Total Silicon Equivalent (mg/m3)	21.098	0.340	26.077	0.448
Removal Efficiency	98.4%		98.3%	



## Existing H<sub>2</sub>S Scrubber




# Gas Compression





# Gas Compression



# Gas filtration





# Gas dehydration





# Gas dehydration and oil removal



# Gas blending





## Standby steam boiler






# Electrical system




# Water treatment- Multimedia filter







# Water treatment – reverse osmosis






# Water treatment - softener







# Water treatment – de-aerator





**Fig.1C:** Operating Principle - Typical Arrangement  
Deaerator size 30 000 lb/hr or less (13 T/hr or less)





# Steam system - HRSG




# Steam system – steam surface condenser






# Steam system – cooling





# Plant electrical system




- CTG 4.5MW
- STG 0.5MW
- IC Engine 3 X 1.4M





## Electricity demands vs onsite power generation (MW)

Average demand	7.5
Peak demand	10
Installed power generation	10.2
Actual power generation	7.1



## Lessons learned

- Complications due to STG addition
  - Requiring high-quality feedwater
  - A complicated steam handling system
- Economizer addition to HRSG
  - Stack sulfur buildup
- Steep learning curves for O&M



## Five contracts

- Consulting contract
  
- Three equipment pre-purchase contracts
  - CTG/HRSG
  - Standby Steam boiler
  - Siloxane removal
  
- Construction contract

## Project Schedule

- Design completed in March 2019.
- Construction started in July 2019
- In-service from January 2023
- Substantial Completion in December 2024



# Acknowledgement

- Andy Mah P.Eng , the co-author

**Calgary**



**Questions?**