

Jarrett Carriere, P.Eng., CEM.
Associate, Chief Energy Systems Engineer
jcarriere@jlrichards.ca

November 8, 2022

Your Vision on the Horizon



Platinum
member





Multidisciplinary Services




Architecture



Civil




Electrical



Energy Systems




Environmental



Mechanical




Planning




Structural



Innovative Energy




- Advisory Services - Energy Assets
- Energy & Carbon in Buildings
- Energy & Carbon in Environmental Infrastructure
- Energy & Carbon in Mining
- Energy & Carbon Strategy
- Renewable Energy Supply & Storage



Background Cornwall WWTP



- The City of Cornwall is studying a co-digestion initiative to transition to a Waste Recovery Facility (WWRF).
- Intent is to see source separated organics being pre-treated and added to the existing digestion system **to increase biogas production**
- Collect digester gas and upgrade to Renewable Natural Gas to sell.
- Minimize on-site consumption of digester gas to maximize collection.
- Reduce GHG emissions



The biogas from the digestion process is currently utilized in the plants central hydronic heating system.



Purpose Feasibility Study

Can we *eliminate* on-site consumption of fuel (biogas & NG) using Wastewater heat recovery?



Procedure


- Review of Existing Systems
 - Thermal Resource Assessment
 - Technology Review
 - Concept Design
 - Financial Analysis
 - Recommendations & Next Steps
-



Existing Systems Review

.....


Cornwall WWTP Existing Heating System



Cornwall WWTP

Gas production/ consumption

Annual heat demand
>3,000 MWh







Effluent Thermal Resource



Effluent Temperature




Effluent Temperature



Effluent Flow


.....

— Daily Maximum — Daily Average — Daily Minimum




Effluent Temperature


— Daily Maximum — Daily Average — Daily Minimum




Effluent Thermal Resource



Effluent Thermal Resource



Effluent Thermal Resource







Technology Review & Concept Design

.....


Basic Concept Design Heat Pump



Heat Exchanger Sample Products



Conventional Flat Plate




HUBER RoWin Heat Exchanger
Self cleaning & Designed for
wastewater and sludge.




*Lakos Self Cleaning Pump Intake
Screen*

Effluent Intake/ HX location



Concept Design





Financial Analysis & GHG Savings



Heat Recovery Opinion of Probable Cost

Description	Cost	Comments
Equipment (installed)	\$1,250,000	Includes heat exchanger, heat pumps, BAF effluent pumps, glycol pumps, glycol make up system and expansion tank, replacement of existing unit heaters (where required), and primary feed pumps.
Piping	\$350,000	Piping to/from the BAF feeding the heat exchanger in the Work Shop, piping within the work shop connecting the heat pumps and the heat exchanger, tie to the existing piping network, New secondary piping connecting the BAF hydronic loop to the upgraded pipe distribution network.
Demolition	\$30,000	Removal of unit heaters. Removal of piping around the existing boilers made obsolete with proposed design.
Electrical & I/C	\$ 350,000	Power and controls to install the heat pumps and associated accessories.
Commissioning	\$20,000	Commissioning of the entire heating system.
Total OPC	\$2,000,000	

Heat Recovery GHG and Cost Savings

Reference Scenario:	NG (Current Rate)	NG (170\$/t Carbon Tax)	RNG Conservative Case	RNG Optimistic Case
System Electricity Consumption	830 MWh			
Avoided NG/ RNG Consumption (*)	(3,105 MWh)			
GHG Reduction	550 tCO _{2e}			
GHG percent Reduction	99.8%			
NG/ RNG Rate	0.03 \$/kWh	0.06 \$/kWh	0.072 \$/kWh	0.09 \$/kWh
System Electricity Costs (Annual)	\$83,000	\$83,000	\$83,000	\$83,000
Avoided NG/ RNG Annual Costs (Annual)	(\$93,000)	(\$174,000)	(\$206,000)	(\$254,000)
Annual Cost Savings	\$10,000	\$91,000	\$140,000	\$197,000
OPC	\$2,000,000	\$2,000,000	\$2,000,000	\$2,000,000
Simple Payback (Years)	NA	22	16	12




Next Steps



Recommendations

Design & Cost Optimization

- Smaller heat pump/ heat exchanger?
 - Meet a base load, supplement with “peaking” boiler, or
 - Digester heating only
- High temperature or cascading heat pumps?
- Sell heating (and cooling) to neighbors?





Acknowledgments



J.L. Richards

ENGINEERS · ARCHITECTS · PLANNERS



Jarrett Carriere, P.Eng., CEM.
Chief Energy Systems Engineer

jcarriere@jlrichards.ca



Platinum
member

www.jlrichards.ca

Thank You!



J.L. Richards

ENGINEERS · ARCHITECTS · PLANNERS



Jarrett Carriere, P.Eng., CEM.
Chief Energy Systems Engineer

jcarriere@jlrichards.ca



Platinum
member

www.jlrichards.ca