

# CASE STUDY: Process to Update the Region of Waterloo's Raw Water Intake Protocol during Grand River Watershed Upsets

---

CWWA, NWWC 2022  
NOVEMBER 8, 2022



Region of Waterloo




# Agenda

---

- Mannheim WTP: A brief overview
- Protocol History
- Rational and Approach for Updating Protocol
- Operation and Updates of the Protocol
- Supporting tools and calculators developed for use
  - Time of travel calculator

# Mannheim Water Supply

---



# Mannheim Water Supply

---


- Master plan completed in the 1980's
- Recommendation to augment groundwater supply with surface water from the Grand River
  - Continued growth of the surface water supply via aquifer storage and recovery (ASR)
- Planned increase of plant capacity
- Grand River contributes 20 to 25% of supply

# Mannheim Water Supply

---

## Hidden Valley

- Intake weir and low lift pumping station
- Raw water reservoir
- High lift pumping station and transmission main



# Mannheim Water Supply

---

## Mannheim WTP

- Fully conventional plant with: High-rate sedimentation, ozonation, deep bed biologically active filtration, UV and chlorine disinfection



# Protocol History

---

- April of '93 *Cryptosporidiosis* outbreak in Milwaukee identified
  - Confirmed to be linked to the surface water treatment plant.
    - 400,000 customers affected.
    - 69 deaths
    - Over \$0.5 B spent to upgrade the WTP, ozone implemented
  - Long-lasting change to treatment objectives in the industry

# Protocol History

---

- Spring of '93 *Cryptosporidiosis* outbreak in the Region of Waterloo flagged by Medical Officer of Health
  - Very similar timing to Milwaukee
  - Suspected link to surface water sources
    - K70's and K80's, Winterbourne and Mannheim taken off-line as a precaution
  - Never positively linked to the surface water supply








# Protocol History

---


- Spring of '93 *Cryptosporidiosis* outbreak in the Region of Waterloo flagged by Medical Officer of Health
  - First SOP developed to bring these sources back on-line which evolved into the current SOP.
  - Very conservative approach taken to get the plant and other sources back on-line ASAP prior to peak water demand - many of these measures remained in place for close to 30 years
    - Close for all WWTP by-passes and spills
    - Shut-down at 25 NTU

# Rational and Approach for Updating Protocol

<p><b>Advances in treatment barriers:</b> i.e. UV disinfection, Advanced oxidation treatment, enhanced filtration, etc.</p>	
<p><b>Source Water Protection Legislation</b></p>	
<p><b>Advancement of QMRA to assess health related risk to source water pathogens.</b></p>	
<p><b>Advancement of hydrologic modelling</b> (estimating watershed time of travel and particulate dispersion)</p>	
<p><b>Advancement of monitoring technologies (early warning system)</b></p>	

# Rationale and Approach for Updating Protocol

---



# Rational and Approach for Updating Protocol

---

*'The central purpose of this protocol review and updating exercise was to determine if more operational flexibility can be supported by the current understanding of the pertinent technology and science.'*

# Operation and Updates of the Protocol

---

- Three scenarios to trigger use of the SOP
  - High turbidity
  - WWTP bypass
  - Chemical/biological spill
- Dictates shutting down of HV and WTP
  - Upstream OR downstream
  - Director's approval require to re-open


# Operation and Updates of the Protocol

---

## **SOP CHANGES – GOVERNANCE**

- An annual review of the type and severity of spills resulting in intake shutdowns that have occurred over the year
  - If warranted by this review, a review team will be assembled to update the SOP.
- If a significant or unusual event occurs in the system, after following the SOP, a special review of the SOP will immediately follow.

# Operation and Updates of the Protocol





# Operation and Updates of the Protocol

---



## SOP Changes – Significant Changes

- Decentralization of decision making where possible
- **Intake can remain open for all WWTP by-passes except Waterloo WWTP**
  - Justified using a QMRA assessment
- HVR minimum operating level adjusted upward
- **Time of travel calculator**
- CT disinfection calculator updated



# QMRA Analysis in Support of Protocol Changes

---

Scenario	Coagulation/ Flocculation / Sedimentation	Filtration (Rapid Granular)	Ozone Disinfection	UV Disinfection	Chlorine Disinfection
1	✓	✓			
2	✓	✓		✓	
3	✓	✓	✓	✓	

Process  
Sensitivity

Parameter	Minimum	Maximum
Initial Ozone Concentration	0.0 mg/L	5.0 mg/L
UV Disinfection	0.0 mJ/cm <sup>2</sup>	22 mJ/cm <sup>2</sup> *
Water Temperature	0.5°C	30 °C
Blending With GW	18.9%	70.1%
Population	79,514	294,918

Process and population  
ranges

\* UVDGM 4-log Cryptosporidium inactivation

# QMRA Analysis in Support of Protocol Changes

---

Treatment Barrier	Scenario 1 (Winter & Summer)	Scenario 2 (Winter & Summer)	Scenario 3 (Winter)	Scenario 3 (Summer)
Coagulation, Flocculation & Sedimentation	1.86	1.86	1.86	1.86
Filtration – Rapid Granular (coagulation/sedimentation)	2.41	2.41	2.41	2.41
Primary Disinfection 1 – Ozone	0.00	0.00	1.01	1.83
UV Disinfection	0.00	4	4	4
Overall Log Reduction	4.27	8.27	9.28	10.10

Unit Process and Total Performance

Scenario	<i>Cryptosporidium</i> Oocysts per 100L
Scenario 1 (Winter & Summer)	40
Scenario 2 (Winter & Summer)	$1.0 \times 10^6$
Scenario 3 (Winter)	$9.0 \times 10^7$
Scenario 3 (Summer)	$>9.0 \times 10^7$

Maximum oocyst concentration in raw water that plant can handle while meeting Health Canada DALY.

# QMRA Analysis in Support of Protocol Changes

---


In 6 major studies from 2002 to 2014, hundreds of samples, the worst-case *Cryptosporidium* concentration recorded – **900** oocysts per 100L.

Worst case oocyst concentration measured in literature in raw sewage, assume by-pass and summer (most conservative) dilution rates – 700 oocysts/100L at Elmira, 1150 oocysts/100L Waterloo

Waterloo WWTP excluded

- Close proximity with potentially very low dilution factor at Waterloo WWTP (19%)

# Operation and Updates of the Protocol



# Supporting Tools

---

## TIME OF TRAVEL CALCULATOR

Why needed?

- Chemical/biological spill
  - Environmental Enforcement and Laboratory Services (EELS) takes the call and notifies water services
  - Water services calls GRCA for river ToT
  - Assess location of leading edge of plume – US or DS of intake at time of closing of intake
    - If DS, use ToT Tool to determine location of plume in the Mannheim Water Supply system

# Supporting Tools

---

## TIME OF TRAVEL CALCULATOR

- Includes Hidden Valley system and Mannheim WTP
- Estimates travel time from the Grand River to the Mannheim WTP clearwell
- Calculations are conservative
  - using  $T_{10}$  contact time concept
  - Maximum flow through one side of plant is entered
- Data validation included

## Automated Calculator for ToT to Elements of the Hidden Valley System

USER INPUT  
CALCULATED VALUE

Enter Flow through the Hidden Valley High-Lift in L/s

Q =  L/s

Enter HV Reservoirs Cells 1 - 4 On/Off Status and Levels in %

Cell 1 =  Online/Offline  %  
 Cell 2 =  Online/Offline  %  
 Cell 3 =  Online/Offline  %  
 Cell 4 =  Online/Offline  %

Cells past the water draw point are not included in the travel time calculation, and will be greyed out.

HV Reservoir Cells 1 - 4 Baffling Factor (T10/T Ratio) determined by which cell is used to draw water.

Cell 1 =  Water Draw  BF  
 Cell 2 =  Water Draw  BF  
 Cell 3 =  Water Draw  BF  
 Cell 4 =  Water Draw  BF



## Automated Calculator for ToT to Processes of the Mannheim WTP

Enter maximum single-train flow:

Q =  L/s

Assumptions for Mannheim WTP ToT:

1. Plant operating at 100% water level (not overflow)
2. Textbook porosity value of 0.5 for GAC filters (Table 8-1, Water Quality and Treatment, AWWA, 4th Ed.)

### Calculated ToT to Reach HV System Element:

Reservoir Cell 1	=	0 hrs	28 mins
Reservoir Cell 2	=	5 hrs	47 mins
Reservoir Cell 3	=	11 hrs	7 mins
Reservoir Cell 4	=	16 hrs	27 mins
Raw Water Main	=	18 hrs	14 mins
Raw Water Storage	=	24 hrs	26 mins

### Calculated ToT to WTP System Processes:

Flocculators (first in series)	=	14 mins	24 hrs	40 mins
Flocculators (second in series)	=	16 mins	24 hrs	42 mins
Plate Settlers	=	17 mins	24 hrs	44 mins
Settler Trough	=	20 mins	24 hrs	46 mins
Ozone Contactors	=	20 mins	24 hrs	46 mins
Filters	=	23 mins	24 hrs	49 mins
Treated Water Cell (Clearwell)	=	32 mins	24 hrs	58 mins


### Cumulative Time:



# In Summary:

---

- Incorporated latest understanding of science and technology
  - Ex. QMRA analysis for leaving intake open
- Decentralization of decision-making process
- Reduce downtime of the WTP
- Tools to supplement decision-making process

 Region of Waterloo	<b>WATER SERVICES STANDARD OPERATING PROCEDURE (SOP)</b>	SOP#	3597727
		Revision Date	NOVEMBER 16, 2021
		Approved by	WATER SERVICES
		Section	O&M
<b>PROTOCOL FOR OPERATING THE HIDDEN VALLEY LOWLIFT INTAKE DURING GRANDRIVER WATERSHED UPSETS</b>			



# Thank You!



## Co-Author

Olga Vrentzos – Region of Waterloo

## Acknowledgments

Sabrina Chang – C3 Water Inc.

Sammy Hiseler – C3 Water Inc.

Mike McKie – C3 Water Inc.